Contents lists available at ScienceDirect



Electrical Power and Energy Systems

journal homepage: www.elsevier.com/locate/ijepes



Increase of capacity in electric arc-furnace steel mill factories by means of a demand-side management strategy and ampacity techniques



M. Manana^{a,*}, A.F. Zobaa^b, A. Vaccaro^c, A. Arroyo^a, R. Martinez^a, P. Castro^a, A. Laso^a, S. Bustamante^a

^a University of Cantabria, Spain
 ^b Brunel University London, UK
 ^c University of Sannio, Italy

ARTICLE INFO

Keywords: Demand-side management Electric arc-furnace Ampacity

ABSTRACT

An electric arc-furnace is a complex industry which demands high levels of electrical energy in order to heat iron materials and other additives needed for the production of cast iron and/or steelmaking. The cost of the electrical energy demanded by the factory during the production can be greater than 20% of the overall cost. This kind of arc-furnace allows the production of steel with levels of scrap metal feedstock up to 100%. From an electrical point of view, the factory size in terms of its maximum apparent power demanded from the grid is designed to make use of the static capacity of the transmission line that supplies the energy. In that case, it is not possible to increase the power of the factory above the static rating by adding new facilites without installing new transmission infrastructures. This paper presents a methodology that allows an increase in net power of an arc-furnace factory without installing new transmission lines. The novelty of the proposed solution is based on a mix strategy that combines Demand-Side Management (DSM) methodologies and the use of ampacity techniques according IEEE 738 and CIGRE TB601.

The application of DSM methodologies provides an improvement in the sustainability of not only the industrial customer but also in the overall grid. As a secondary effect, it reduces operational costs and the greenhouse gas emissions.

The proposed methodology has been tested in an arc-furnace factory located in the North of Spain.

1. Introduction

An electric arc furnace (EAF) is a furnace that heats charged material by using an electric arc. They are usually devoted to the production of cast iron and/or steelmaking. From an energy point of view, it is a load that it is intensive in terms of its power demanded from the grid [1].

As the electrical energy consumption in an EAF based steel factory is typically greater than 20% of the overall production cost, most of the modeling effort has been devoted to the analysis of energy comsuption considering cost minimization [2] as the main target [3]. From the point of view of predicting the electrical energy consumption of Electric Arc Furnaces using statistical Modeling it is possible to find several approaches using both linear and non-linear models. Table 1 summarizes several contributions in the field of EAF modeling.

Despite the fact that all the references provide useful methods for predicting energy demand and other physical parameters related to the EAF there is not any reference that provides a general approach considering not only the EAF but also the rest of loads included in the mill factory. In addition, the models are not extended to the problem of optimizing the value of the current demanded by the overall factory.

On the other hand, Demand Side Management (DSM) can be considered as a set of measures defined in order to improve the way in which energy is demanded at the consumption side [18]. Although DSM has traditionally been applied to residential loads, it has also been used in industrial environments [19].

In [20], the potential of DSM methodologies was investigated in applications specifically devoted to power-intensive industries. The main conclusion in the case of EAF is that DSM potential is strictly devoted to load shedding. The authors of [21] introduced an optimization method that can be applied to both batch and continuous-type loads.

DSM does not provide a single solution, but an action plan that includes several approaches: i) the improvement of energy efficiency by

* Corresponding author.

E-mail address: mananam@unican.es (M. Manana).

https://doi.org/10.1016/j.ijepes.2020.106337

Received 12 October 2019; Received in revised form 14 June 2020; Accepted 29 June 2020 0142-0615/ © 2020 Elsevier Ltd. All rights reserved.

Table 1

EAF models based on both linear and non-linear approaches. Abbreviations: Multivariate Linear Regression (MLR); Partial Least Squares (PLS); Artificial Neural Networks (ANN); Deep Neural Networks (DNN); Random Forest (RF); Decision Tree (DT); Support Vector Machine (SVM).

Linear	MLR	Köhle [4], Bowman [5], Kleimt [6], Köhle [7] Kirschen [8], Conejo [9], Czapla [10]
Nonlinear	PLS ANN DNN RF DT SVM	Sandberg [11] Baumert [12], Gajic[13], Haupt[14] Chen[15] Haupt[14] Kordos[17] Yuan[16]



Fig. 1. Architecture of a DSM system.

upgrading load technologies, ii) the reduction of energy cost by improving energy tariffs with incentives for specific consumption patterns [22,23] and iii) the application of complex real-time control methodologies of distributed energy resources. In Palensky et al. [24] DSM is categorized into the following list: Energy Efficiency (EE), Time of Use (TOU), Demand Response (DR) and Spinning Reserve (SR).

Fig. 1 summarizes the basic architecture and components of a DSM system that includes elements such as local generators, smart devices, energy storage systems, sensors and energy management units (EMU) [25]. All the elements must to be connected through a communication infrastructure. An external connection via Internet can be provided depending on security issues. The application of DSM can change the operational conditions of the involved elements, forcing the network operator to adjust the capacity ratings [26].

Load control algorithms have to deal with two main tasks:

- 1. Control the overall factory maintaining operational criteria.
- 2. Control each individual load to ensure that the total current demanded is below the dynamic rate. The individual control of loads can be on/off or proportional depending on the load.

Despite the fact that DSM techniques are well known, it is difficult to find references in which this methodology is applied to EAF applications [27] [28] [29] [30] [31]. Dalle et al. [32] analyzed how DSM can improve the electrode degradation in EAF.

This paper proposes a non-classical application of DSM strategies in which the function to optimize is not economic cost, but the maximum current through the supply infrastructure considering that some loads inside the factory are dispatchables.

In this paper, we propose a methodology that combines both DSM techniques and dynamic line rating in order to increase the power capacity of a large electric arc-furnace factory without upgrading the overhead transmission line that links the factory to the transmission grid. This approach is especially useful in cases in which the factory is near urban areas where the constraints related to the construction of new transmission infrastructures are critical. The paper illustrates the proposed methodology for a real case in which an electric arc-furnace factory needs to increase its power demands, but the overhead infrastructure that supplies energy is already operating following a classical approach near the static limit. In the real case under study, the only available solution is to install a new transmission line or repower the existing one. In this research work, DSM combined with ampacity techniques is shown to increase the capacity of existing factories. The rest of this paper is organized as follows: Section 2 gives a general introduction to the way in which electric arc-furnaces demand energy. In Section 3, a demand-side management approach devoted to this type of factories is defined. In Section 4 we introduce the ampacity formulation that allows one to extend the capacity of the line according the weather conditions. In Sections 5 and 6 we introduce the concept of Quality of Service, that defines the impact of DSM and the optimization problem. In Section 7 the proposed methodology is applied to a real case considering a year of sampled data. Finally, the paper summarizes our conclusions and remarks on future directions.

2. Electric arc-furnace energy demand

A steel factory is a complex system that integrates two different sets of loads:

- High-energy demand loads with poor power quality requirements such as the electric arc-furnace.
- Medium and low-energy demand loads with restrictive power quality preliminary conditions (e.g., electronic controllers, power electronic devices, electrical drives, sensitive instrumentation).

Fig. 2 shows the basic architecture of the electric-arc furnace factory. The industry is supplied by two overhead lines at 220 kV \odot and 55 kV \odot . The 220 kV line supplies energy to the electric arc-furnace used for steelmaking. This consumption is isolated from the rest of loads due to the high level of disturbances produced. The 55 kV line supplies energy with better power quality levels to several sets of loads:

- Auxiliary services ③. All the electrical consumption of the treatment plant, including blowers, air filters, air compressors and other auxiliary elements.
- Hot-rolling mill (). The steel billets manufactured by the electric arcfurnace are processed by circulating through several sets of pairs of rollers to reduce the thickness and making the thickness uniform.

The current rate of both lines has been defined considering a conservative approach. In the case of the 55 kV line, the current rate is 560 A. Considering a nominal voltage of $U_N = 55$ kV, the maximum capacity of this line is $S_N = 53.34$ MVA. The aggregated consumption of this line is summarized in the histogram shown in Fig. 3.

A parameter defined as *AOM* (Absolute Operation Margin) is defined in order to measure the available capacity of the transmission line that supplies energy to the steel factory. This parameter can be specified in terms of current or power.

The orange area in Fig. 3 is the Absolute Operation Margin of the current (AOM_I) defined as the difference between the static rate of the line I_{SR} that supplies energy to the factory and the maximum value of current I_{max} demanded by the factory.

$$AOM_I = I_{SR} - I_{max} \tag{1}$$

It is well known that achieving a uniform temperature distribution



Fig. 2. Simplified electric diagram of an electric arc-furnace factory with measurement points.

in the billets is not a trivial task. The factory is considering an increase in the power demanded by the 55 kV line that will be produced by a new intermediate Induction Reheating Oven (IRO) (\odot in 2) with a nominal power of 6 MW. The purpose of this oven is to compensate the radial temperature gradient in the billets. In addition, it restores the optimum rolling temperature. The estimated histogram of the active power consumption is summarized in Fig. 4.

Fig. 4 shows that the increase in the power demanded by the factory moves the value of AOM_l from a positive to a negative one, $AOM_{l'}$. In this new operating condition, the maximum current $I'_{max} > I_{SR}$ is inside the overcurrent zone, and thus the overhead line protection will be trigged.

The operational margin AOM can be incremented in two main ways:

1. By increasing the transmission line static rate S_{SR} . Ampacity techniques can increase the dynamic capacity of transmission lines without the need to upgrade the infrastructure.

2. By reducing the maximum value of the demanded apparent power S_{max} . Demand-side management techniques can be used to control the overall set of loads inside the factory [33]. This technique has to be applied considering a trade-off between current reduction and Quality of Service.

The methodology is summarized in Fig. 5. Both techniques are reviewed in the next sections.

3. Demand-side management techniques

From a general point of view, all the electric loads that can be found in the factory can be classified in three main sets according to the way in which they are controlled, the constrains defined by the manufacturing process, and the quality of service [25]:

- 1. Fixed.
- 2. Shiftable.
- 3. Elastic.

The classical approach followed by the company in the past for the billet pre-heating, was to perform this task with a natural gas oven. This strategy is not as efficient as the equivalent one based on induction, because of the way in which the billet is heated. Induction heating is more efficient and also more flexible since the billet is heated in a more homogeneus way, and the system can be switched on and off quickly.

Considering that time is sampled in slots, then for each time slot $n \in N$, the total active power p_n^{TOT} can be computed as follows

$$p_n^{TOT} = \sum_{f \in \mathcal{F}} p_{fn}^{\mathcal{F}} + \sum_{s \in \mathcal{S}} p_{sn}^{\mathcal{S}} + \sum_{e \in \mathcal{E}} p_{en}^{\mathcal{E}} \quad \forall \ n \in \mathcal{N}$$

$$\tag{2}$$

where $p_{fn}^{\mathcal{F}}$ is the power demanded by fixed devices, $p_{sn}^{\mathcal{S}}$ is the power consumption of shiftable loads and $p_{en}^{\mathcal{E}}$ is the power demanded by elastic loads.

3.1. Fixed loads

A fixed load \mathcal{F} is defined as a device or set of devices that cannot be controlled by the end-users. Both power consumption and operational time have fixed values (e.g., devices devoted to security issues, lights). Each device with a fixed active power $f \in \mathcal{F}$ is characterized by its active power $p_{fn}^{\mathcal{F}}$, considering all the time slots of the period that is analized $n \in \mathcal{N}$.



Fig. 3. Histogram of the current demand at 55 kV line.



Fig. 4. Histogram of the new demand at 55 kV line.



Fig. 5. Methodology for the increment of capacity in industrial factories using combined DSM and DLR.

3.2. Shiftable loads

A shiftable load is a device or set of devices with an active power consumption that has a fixed profile where its starting time can be controlled in a certain range. These loads are represented by S, and each device $s \in S$ has a length of D_s^S slots. The power profile l_{sd}^S of a device s in the d-th time slot of each individual profile (with $d \in D_s^S = \{1, 2, ..., D_s^S\}$) can be considered as constant. The main task of the DSM during the operation of shiftable loads is to define, for each device $s \in S$, the sample at which the device starts to run. The operating condition will continue during a set of consecutive time slots $N_s^S \subseteq N$. The set N_s^S must be in a range defined by a minimum starting-time slot ST_s^S and a maximum end-time slot ET_s^S defined by the production schedule.

The scheduling decision problem of each shiftable device $s \in S$ is defined by a binary variable x_{sn}^S for each sample $n \in N$. The binary variable x_{sn}^S is one if the load *s* starts in the sample *n* and zero otherwise so $x_{sn}^S \in \{0, 1\}$. In addition, it is necessary to define a constraint that makes compulsory the operation of *s* one time within the time slot N_s^S [34,35].

$$\begin{cases} \sum_{n=ST_s^S}^{ET_s^S - D_s^S + 1} x_{sn}^S = 1 \quad \forall \ s \in S \\ x_{sn}^S = 0 \qquad \qquad \forall \ s \in S, \ n \in N \setminus N_s^S \end{cases}$$
(3)

According to Eq. (3) the power p_{sn}^S demanded by each shiftable load $s \in S$ in each time slot $n \in N$ can be computed as

$$p_{sn}^{\mathcal{S}} = \sum_{d \in D_{\mathcal{S}}^{\mathcal{S}}: d \leq n} l_{sd}^{\mathcal{S}} \cdot x_{s(n-d+1)}^{\mathcal{S}} \quad \forall s \in \mathcal{S}, n \in \mathcal{N}$$
(4)

3.3. Elastic loads

An elastic load is a device or set of devices, \mathcal{E} , whose instantaneous power demand can be managed by the DSM controller. Each device $e \in \mathcal{E}$ is represented by $p_{en}^{\mathcal{E}}$ in each time slot $n \in N$. There are two main types of elastic loads $e \in \mathcal{E}[36,37]$.

- Energy-based elastic loads ($e \in \mathcal{E}^{EB}, \mathcal{E}^{EB} \subseteq \mathcal{E}$).
- External-based elastic loads ($e \in \mathcal{E}^{XB}, \mathcal{E}^{XB} \subseteq \mathcal{E}$).

The elastic load fulfills the condition

$$\mathcal{E} = \mathcal{E}^{EB} \cup \mathcal{E}^{XB}$$

3.3.1. Energy-based elastic loads

Energy-based elastic loads are sets of devices with a prescribed energy requirement. They are defined by a subset $\mathcal{E}^{EB} \subseteq \mathcal{E}$. All the appliances that belong to this group $e \in \mathcal{E}^{EB}$ demand a total amount of energy $E_{e,TOT}^{\mathcal{E}^{EB}}$ in the range of time slots $\mathcal{N}_{e}^{\mathcal{E}^{EB}} \subseteq \mathcal{N}$ defined by the range of time slots $[ST_{e}^{\mathcal{E}^{EB}}, ET_{e}^{\mathcal{E}^{EB}}]$. The energy $E_{e,TOT}^{\mathcal{E}^{EB}}$ can be computed as

(5)

$$E_{e,TOT}^{\mathcal{E}^{EB}} = \mu \sum_{n=ST_e^{\mathcal{E}^{EB}}}^{ET_e^{\mathcal{E}^{EB}}} p_{en}^{\mathcal{E}^{EB}} \quad \forall \ e \in \mathcal{E}^{EB}$$
(6)

where μ is a parameter equivalent to the time that depends on the duration of time slot ΔT_n with $\mu \leq \Delta T_n$.

3.3.2. External-based elastic loads

Weather-based elastic loads are sets of devices which power demand depends on an external parameter. This external dependency is mainly based on weather conditions. They are defined by a subset $\mathcal{E}^{XB} \subseteq \mathcal{E}$. The external-based power $p_{e}^{\mathcal{E}^{XB}}$ can be represented as

$$p_{en}^{\mathcal{E}^{XB}} = \xi_{en}^{\mathcal{E}^{XB}} \cdot p_{en}^{\mathcal{E}^{XB,NOM}} \quad \forall \ n \in \mathcal{N}$$

$$\tag{7}$$

where $\xi_{en}^{\mathcal{E}^{XB}} \leq 1$ is the external conversion function representing the external parameter or set of parameters which modulate for each $n \in \mathcal{N}$ the power demanded by each load $e \in \mathcal{E}^{XB}$.

3.4. Local energy generators

Some industries have generation systems based on both renewable energies and classical internal combustion engines supplied by gas and fuel. In the case of renewable energy, the total amount of energy supplied, $\pi_n^{\mathcal{R}}$, is only a prediction for each sample $n \in \mathcal{N}$. Weather forecast is one of the most useful tools available for this task. It is assumed that energy produced is only for local consumption. If the energy produced is greater than the demand, then the difference z_n will be injected into the grid for each $n \in \mathcal{N}$. The difference z_n is equal or small that the net value z_n^{net} , where

$$\pi_n^{net} = \max\left[0, \, \pi_n^{\mathcal{R}} - \mu \cdot p_n^{TOT}\right] \quad \forall \ n \in \mathcal{N}$$
(8)

3.5. Energy storage systems

Energy storage systems (ESS) provides a flexible tool to the DSM controller in order to modulate the energy consumption. The ESS can be in one of two states of the set \mathcal{B} : i) charging (ω_{bn}) and ii) discharging $(1 - \omega_{bn})$. It is considered that a slot *n* in which there is no charge or discharge can be considered a discharging state at near-zero discharging rate. The charging rate is defined by r_{bn}^C while discharging rate is represented by r_{bn}^D .

3.6. Energy balancing

Once we know all the elements involved in the energy flux it is possible to define the balance condition for all the values of $n \in N$ according the power flow summarized in Fig. 6.

$$y_n + \pi_n^{\mathcal{R}} + \mu \sum_{b \in \mathcal{B}} r_{bn}^{D} = z_n + \mu \sum_{b \in \mathcal{B}} r_{bn}^{C} + \mu \cdot p_n^{TOT}$$
(9)

In the proposed approach, it is not considered any type of forecasting in level of load at the demand-side [38] as the industrial process is defined in advanced based on production orders.



Fig. 6. Power flows in the factory.

4. Ampacity

From a classical point of view, overhead transmission lines are operated with a fixed value I_{SR} that is computed using conservative weather conditions (wind speed of 0.6 m/s and an ambient temperature of 40 °C). Using another approach, the thermal rating of overhead lines is a parameter that defines their capacity at low current densities (<1.5 A/mm²) and low temperatures (<100 °C). The analysis of capacity can be carried out in static or dynamic conditions. The static rating does not consider variations in weather conditions or current with time. This approach is widely considered from an statistical point of view. When the weather conditions and/or the current change with time it is necessary to extend the analysis to include the thermal capacity of the conductor. The standards IEEE Std 738:2012 [39] and CIGRE TB 601:2012 [40] define a methodology for calculating the thermal rating of overhead lines. They propose methods suitable to compute the temperature in the conductors that are based on the steady state heat balance concept. In spite of the fact that both documents do not provide the same set of equations, the results are rather similar [41]. This approach stablishes that heat gain is equal to heat loss. Additionally both of them take into account meteorological parameters influencing the thermal state of the conductor including the ambient temperature, solar radiation, and wind velocity. However, both methods represent different methodologies of calculation of the heat balance equation. The CIGRE model stablishes the steady-state heat balance equation that is shown in Eq. (10),

$$P_J + P_M + P_S + P_I = P_C + P_R + P_W$$
(10)

where P_J is the Joule heating, P_M the magnetic heating, P_S the solar heating, P_I the corona heating, P_C the convective cooling, P_R the radiative cooling, and P_W the evaporative cooling.

On the other hand the heat balance equation according to the IEEE standard doesn't consider magnetic heating, corona heating and evaporative cooling because their impact is usually insignificant compared with the other terms.

The simplified IEEE equation for non-steady-state heat balance includes the total heat capacity of the conductor mC_p , as shown below

$$P_J + P_S + P_I = P_C + P_R + mC_p \frac{dT_c}{dt}$$
(11)

In addition, the IEEE equation for steady-state heat balance neglects magnetic, corona and evaporative heat losses. In steady-state conditions $\frac{dT_c}{dt} = 0$, so the current rating I_{DR} can be computed as

$$I_{DR} = \sqrt{\frac{P_C + P_R - P_J - P_S}{R(T_{c,avg})}}$$
(12)

The overhead line O_1 (see Fig. 2) is operated following a static approach in which the capacity is defined in steady-state considering an ambient temperature of 40 °C and a wind speed of 0, 6 m/s.

If the line is operated in dynamic mode, then the increment of capacity $\Delta I_{DR} = I_{DR} - I_{SR}$ depends on the weather conditions. The values obtained acording Eq. (12) are theoretical values that have to be limited taking into account the maximum operational limits of underground cable sections, breakers, current transormers, and all the elements connected in series with the overhead cable.

The transmission capacity of the line S_{DR} can be computed as

$$S_{DR} = \sqrt{3} V_{LL} I_{DR} \tag{13}$$

5. Quality of service

The Quality of Service QS is a parameter that refers to the ability of the Energy Control System (ECS) to fulfills all the requirements defined by the set of loads. The total value of the system QS^{TOT} reaches its maximum value when there are no constraints limiting the power demanded by all the loads included in the factory. If the ECS introduces



Fig. 7. Profile of the active power demanded by the factory.

any constrains in the behavior of the loads and the rest of the subsystems (generators and storage devices), then the QS_n^{TOT} at any time *n* will be defined by Eq. 14

$$QS_n^{TOT} = \sum_{f \in \mathcal{F}} QS_{fn}^{\mathcal{F}} + \sum_{s \in \mathcal{S}} QS_{sn}^{\mathcal{S}} + \sum_{e \in \mathcal{E}} QS_{en}^{\mathcal{E}} \quad \forall \ n \in \mathcal{N}$$
(14)

QS is used in order to define a weight for each load as not all the loads play a role with the same importance in the industrial process.

6. Optimization

Considering a power factor almost equal to 1.0, the active power is numerically identical to the apparent power so $P_{DR} \equiv S_{DR}$. Even in a case Optimize $max\{|y_m - z_m|\}$

Input: Loads $(\mathcal{F}, \mathcal{S} \text{ and } \mathcal{E})$, Generators (\mathcal{R}) and Energy Storage

Devices (\mathcal{B})

Output: Best Scenario $(\mathcal{F}_m, \mathcal{S}_m, \mathcal{E}_m, \mathcal{R}_m, \mathcal{B}_m)$ that minimizes

$$|y_n - z_n| \quad \forall n \in \Lambda$$

1 $N_{sim} \leftarrow$ Number of simulations

2 $QS_{min} \leftarrow$ Minimum quality of service

3 $SC_{best} \leftarrow (\mathcal{F}, \mathcal{S}, \mathcal{E}, \mathcal{R}, \mathcal{B})$ Best Scenario

4 for
$$m \leftarrow 1$$
 to N_{sim} do /* Repeat for N_{sim} scenarios */

5 Define Scenario $SC_{best} \leftarrow (\mathcal{F}_m, \mathcal{S}_m, \mathcal{E}_m, \mathcal{R}_m, \mathcal{B}_m)$ /* Scenarios generated using an Optimization Technique */

6 Compute Quality of Service QS_m^{TOT}

7 | if $|y_m - z_m| \leq \xi \cdot P_m^{DR}$ and $QS_m^{TOT} \geq QS_{min}$ then

8 | if
$$SC_m$$
 is best that SC_{best} then /* Heuristic optim. */
9 | $SC_{best} \leftarrow SC_m$
10 | end
11 | end
12 end

13 return SC_{best}

where ξ is the security margin. The optimization process is summarized in Algorithm 1. In the proposed methodology the optimization can be

(15)

in which the PF is not equal to one, it is still possible to extend the

formulation of the problem by applying the Boucherot's theorem to

compute both the active and reactive power. After that, the apparent power can be translated to rms current directly. For any time slot *n* the dynamic power capacity p_n^{DR} defines the upper limit of the power that

can be handled by the infrastructure (see Fig. 7). The mixed constrained

minimization problem may be written as

 $|y_n - z_n| \leq \xi \cdot P_n^{DR}$

 $\left(\mininimize_{\forall n \in \mathcal{N}} \max[|y_n - z_n|] \right)$

subject to



Fig. 8. Dynamic capacity of the transmission line aggregated by season, solar radiation and ambient temperature.

performed using several techniques. In this paper the optimization is carried out using Monte Carlo [42] and Simulated Annealing [43]. It is assumed that Monte Carlo provides a near-optimal solution by sampling variables according specific probability distribution functions. This approach can be useful when the optimization problem has several local optima, the constraints are difficult to define, and the number or type of parameters is high. In spite of the fact that the solution is nearoptimal, the computational burden of this method is low enough to be applied in real-time applications. Shabani et al. [44] propose a probabilistic methodology that can be applied to the computation of power cable ampacity by considering uncertainty of parameters and economic constraints in isolated conductors.

Algorithm 1.

7. Results

The proposed methodology has been applied to the electric arcfurnace factory described in Section 2. The analysis has been carried out measuring weather conditions over the course of one year. Fig. 8 summarizes the values of ampacity ΔI_{DR} during one year of measurements considering several degrees of aggregation (season, ambient temperature, and solar radiation).

Fig. 8 shows that the ampacity is greater that the static rating I_{SR} and the maximum demand I'_{max} most of the time. The aggregated data during a year is summarized in Fig. 9.a.

Fig. 9.b shows the period during which the DTR I_{DR} is smaller than

60 D $P_{SR} = 54.3 \text{ MW}$ AOMActive Power [MW] 4020 P_{BAS} A B 0 feb. 23 mar. 02 mar. 09 mar. 16 Time

Fig. 10. Simulation of the time evolution of the apparent power with the new induction reheating oven.

the required maximum current I'_{max} , and where Δt_{DSM} is equal to 650 h a year, considering that the current demanded by the factory is I'_{max} all the time. In a real case the current is fluctuating below that value so the proposed methodology for DSM will only have to be applied during a small percentage of this period Δt_{DSM} .

Fig. 10 shows the time evolution of the total active power during one month with the simulation of the increase produced by adding the new induction reheating oven P_{IRO} . The values located in areas \bigcirc and \bigcirc in Fig. 10 produce overcurrents that have to be avoided. The points



Fig. 9. (a) Density plot of Ampacity; (b) Hourly distribution of DTR in the line under study.



Fig. 11. Maximum current demanded in the factory as a function of the Quality of Service.

and ${\ensuremath{\textcircled{}}}$ show operation and maintenance operations that stop the factory.

During the periods in which the DTR I_{DR} is smaller than the required maximum current I'_{max} the DSM methodology can be applied. Fig. 11 shows the result of applying two different optimization techniques (Monte Carlo and Simulated Annealing). If the current demanded by the factory has to be reduced down to the Static Rate I_{SR} then it is necessary to decressase the total Quality of Service QS of the factory to QS_A equal to 68.6 if the optimization is performed by means of Monte Carlo or QS_B equal to 82.9 when Simulated Annealing is applied.

8. Conclusions

Demand side management has the potential to provide important benefits to both the distribution network and the consumers. This technique is particularly useful when the loads inside the factory can be aggregated in several sets acording to their behaviour.

In the case of EAF and due to the peak-load demanded by the melting arc furnace, the DSM potential is mainly devoted to load shedding. This is due to the fact that the main aim is to minimize the electricity bill by tracking the time-varying energy price.

This paper presents a novel strategy based on the combination of demand side management and dynamic capacity management of overhead transmission lines. It has been shown that the combined strategy can be succesfully applied to a practical problem.

The proposed methodology has been tested in a real electric arcfurnace factory, where power demand is near the static rating of the overhead transmission line that supplies the energy to the industry. This factory is planning to install a new facility with an active power of 6 MW, so the total power demanded will be greater than the available capacity of the transmission line.

The simulations carried out show that the proposed methodology is able to handle the growth of the power demanded by the factory without the necessity of installing new transmission lines. From a theoretical point of view, DTR increases the capacity of existing transmission infrastructure in a significative way, even during the Summer period in which ambient temperature and wind availability reduce their cooling capacity.

The classical approach with static rating shows that the factory is not able to increase its power by adding a new facility. If 6 MW of additional power are added to the demanded power, then the total power will be above that limit.

The application of ampacity techniques allows the factory to operate without the restriction of power demanded during 8,110 h a year (92.5% of the time). During the periods in which the DTR is below the current demanded by the factory the DSM technique can be applied. Two different optimization techniques have been applied. Simulated Annealing provides better results with a loss of Quality of Service equal to 17.1% in the worst case. The results show that the proposed methodology avoids the installation of a new line or the repowering of the existing one.

CRediT authorship contribution statement

M. Manana: Conceptualization, Methodology, Data curation, Writing - original draft, Supervision, Writing - review & editing. A.F. Zobaa: Conceptualization, Methodology, Writing - review & editing. A. Vaccaro: Writing - review & editing. A. Arroyo: Data curation, Writing - original draft, Writing - review & editing. R. Martinez: Data curation, Writing - original draft, Writing - review & editing. P. Castro: Visualization, Investigation, Writing - review & editing. A. Laso: Visualization, Investigation, Writing - review & editing. S. Bustamante: Visualization, Investigation, Writing - review & editing.

Declaration of Competing Interest

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

Acknowledgments

This work was supported by the EU Regional Development Fund (FEDER) and the Spanish Government under the R + D initiative RETOS-COLABORACION with references RTC-2015–3795-3 and RTC-2017–6782-3. The authors also acknowledge Viesgo and GSW for their support.

Appendix A. Supplementary material

Supplementary data associated with this article can be found, in the online version, at https://doi.org/10.1016/j.ijepes.2020.106337.

References

- He Kun, Wang Li. A review of energy use and energy-efficient technologies for the iron and steel industry. Renew Sustain Energy Rev 2017;70:1022–39.
- [2] Carlsson Leo S, Samuelsson Peter B, Jonsson Par G. Predicting the electrical energy consumption of electric arc furnaces using statistical modeling. Metals 2019;9(9).
- [3] Saboohi Yadollah, Fathi Amirhossein, Skrjanc Igor, Logar Vito. Optimization of the electric arc furnace process. IEEE Trans Industr Electron 2019;66(10):8030–9.
- [4] Köhle S. Variables influencing electric energy and electrode consumption in electric arc furnaces. MPT Metallurg Plant Technol Int 1992;6:48–53.
- [5] Bowman Ben. Performance comparison update AC vs DC furnaces. Iron Steel Eng 1995;72(6):26–9.
- [6] Kleimt B, Köhle S. Power consumption of electric arc furnaces with post-combustion. MPT Metallurg Plant Technol Int 1997;20(3):56–7.
- [7] Köhle S, et al. Improving the productivity of electric arc furnaces. European Commission. Technical Steel Research., ISBN 92-894-6136-5; 2003.
- [8] Kirschen Marcus, et al. Models for EAF energy efficiency. Steel Times International; 2017.
- [9] Conejo A, Cardenas J. Energy consumption in the EAF with 100% DRI. In: AISTechiron and steel technology conference proceedings., vol. 1; 2006. p. 529–35.
- [10] Czaplal M, et al. The optimisation of electric energy consumption in the electric arc furnace. Arch Metallurgy Mater 2008;53(2):559–65.
- [11] Sandbergl E, et al. Scrap management by statistical evaluation of EAF process data. Control Eng Pract 2007;15(9):1063–75.
- [12] Baumert JC, et al. Improved control of electric arc furnace operations by process modelling. European Commission. Technical Steel Research., ISBN 92-894-9789-0; 2005.
- [13] Gajicl D, et al. Modelling of electrical energy consumption in an electric arc furnace using artificial neural networks. Energy 2016;108:132–9.
- [14] Haupt M, et al. Influence of input-scrap quality on the environmental impact of secondary steel production. J Indust Ecol 2017; 21(2): 391–401.
- [15] Chen C, et al. Energy consumption modelling using deep learning technique a case study of EAF. In: Proceedings of the 51st CIRP conference on manufacturing systems, Stockholm, Sweden, vol. 72; 2018. p. 1063–8.
- [16] Yuan P, et al. Endpoint prediction of EAF based on G-SVM. J Iron Steel Res 2006; 18(10): 7–10.
- [17] Kordos M, Blachnik M, Wieczorek T. Temperature prediction in electric arc furnace with neural network tree. International Conference on Artificial Neural Networks

ICANN 2011. October 2011. p. 71-8.

- [18] Runnels JE, Whyte MD. Evaluation of demand-side management. Proc IEEE 1985;73(10):1489–95. https://doi.org/10.1109/PROC.1985.13320.
- [19] Gholian A, Mohsenian-Rad H, Hua Y. Optimal industrial load control in smart grid. IEEE Trans Smart Grid 2016;7(5):2305–16. https://doi.org/10.1109/TSG.2015. 2468577.
- [20] Paulus M, Borggrefe F. The potential of demand-side management in energy-intensive industries for electricity markets in germany. Appl Energy 2011;88(2):432–41.
- [21] Ashok S. Peak-load management in steel plants. Appl Energy 2006;83(5):413-24.
- [22] Reka SS, Ramesh V. Industrial demand side response modelling in smart grid using stochastic optimisation considering refinery process. Energy Build 2016;127:84–94. https://doi.org/10.1016/j.enbuild.2016.05.070.
- [23] Ramin D, Spinelli S, Brusaferri A. Demand-side management via optimal production scheduling in power-intensive industries: The case of metal casting process. Appl Energy 2018;225:622–36.
- [24] Palensky P, Dietrich D. Demand side management: demand response, intelligent energy systems, and smart loads. IEEE Trans Industr Inf 2011;7(3):381–8. https:// doi.org/10.1109/TII.2011.2158841.
- [25] Barbato A, Capone A. Optimization models and methods for demand-side management of residential users: a survey. Energies 2014;7(9):5787. https://doi.org/ 10.3390/en7095787.
- [26] McBee KD, Chong J, Rudraraju P. Demand side management effects on substation transformer capacity limits. Appl Sci 2019;9–16:3266–85. https://doi.org/10. 3390/app9163266.
- [27] Zhang Xiao, Hug Gabriela, Harjunkoski Iiro. Cost-effective scheduling of steel plants with flexible EAFs. IEEE Trans Smart Grid JAN 2017;8(1):239–49.
- [28] Nolde Kristian, Morari Manfred. Electrical load tracking scheduling of a steel plant. Comput Chem Eng 2010; 34(11): 1899–903.
- [29] Hait Alain, Artigues Christian. On electrical load tracking scheduling for a steel plant. Comput Chem Eng 2011; 35(12): 3044–7.
- [30] Castro Pedro M, Sun Lige, Harjunkoski Iiro. Resource-task network formulations for industrial demand side management of a steel plant. Indust Eng Chem Res 2013; 52(36):13046–58.
- [31] Harjunkoski I, Grossmann IE. A decomposition approach for the scheduling of a steel plant production. Comput Chem Eng 2001; 25(11–12): 1647–60.
- [32] Dalle G, Hernandez J, Harjunkoski I, Onofri L, Engell S. Demand side management

scheduling formulation for a steel plant considering electrode degradation, 12th IFAC symposium on dynamics and control of process systems, including Biosystems DYCOPS 2019. IFAC-PapersOnLine 2019;52(1):691–6. https://doi.org/10.1016/j. ifacol.2019.06.143.

- [33] Dehghanpour K, Afsharnia S. Designing a novel demand side regulation algorithm to participate in frequency control using iterated mappings. IET Gen Transm Distrib 2014;8(10):1687–99. https://doi.org/10.1049/iet-gtd.2013.0701.
- [34] Goudarzi H, Hatami S, Pedram M. Demand-side load scheduling incentivized by dynamic energy prices 2011:351–6. https://doi.org/10.1109/SmartGridComm. 2011.6102346.
- [35] Vardakas JS, Zorba N, Verikoukis CV. Performance evaluation of power demand scheduling scenarios in a smart grid environment. Appl Energy 2015;142:164–78. https://doi.org/10.1016/j.apenergy.2014.12.060.
- [36] Agnetis A, De Pascale G, Detti P, Vicino A. Load scheduling for household energy consumption optimization. IEEE Trans Smart Grid 2013;4(4):2364–73. https://doi. org/10.1109/TSG.2013.2254506.
- [37] Deng R, Yang Z, Chen J, Chow M-Y. Load scheduling with price uncertainty and temporally-coupled constraints in smart grids. IEEE Trans Power Syst 2014;29(6):2823–34. https://doi.org/10.1109/TPWRS.2014.2311127.
- [38] Glavan M, Gradisar D, Moscariello S, Juricic D, Vrancic D. Demand-side improvement of short-term load forecasting using a proactive load management – a supermarket use case. Energy Build 2019;186:186–94.
- [39] IEEE Standard for calculating the current-temperature of bare overhead conductors, IEEE Std 738-2012 Draft 10 (Revision of IEEE Std 738-2006); 2012: 1–67.
- [40] CIGRE TB601. Guide for thermal rating calculations of overhead lines. WG B2.43. December 2014.
- [41] Arroyo A, Castro P, Martinez R, Manana M, Madrazo A, Lecuna R, et al. Comparison between ieee and cigre thermal behaviour standards and measured temperature on a 132-kV overhead power line. Energies 2015;8(12):12391. https://doi.org/10. 3390/en81212391.
- [42] Kroese DP, Taimre T, Botev ZI. Handbook of Monte Carlo methods. John Wiley & Sons; 2011.
- [43] van Laarhoven PJM, Aarts EHL. Simulated annealing: theory and applications. Netherlands: Springer; 1987.
- [44] Shabani H, Vahidi B. A probabilistic approach for optimal power cable ampacity computation by considering uncertainty of parameters and economic constraints. Int J Electrical Power Energy Syst 2019;106:432–43.